


PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. 475Date : 24

It is certified that an inspection team headed by MR RAMESH (Name of Officers
 with designation) from श. नमोपारी नगर निगम कोटा (Name of
 Department/Office) inspected the SHIVJYOTI CONVENT SCHOOL,
SHRINATHPURAM - D, KOTA (Name & Address of
 the School) on 17/07/2025 and found that the SHIVJYOTI CONVENT
SCHOOL, SHRINATHPURAM - D, KOTA (Name of school) has safe
 drinking water facilities for the students and members of staff of the institution and is maintaining
 the hygienic sanitation condition in the school building & the campus as per the norms
 prescribed by the Central/State/U.T Govt.

The above valid for a period of 01 year.

Signature with Seal : Name : Designation : स्वास्थ्य निरीक्षक
नगर निगम कोटा दक्षिण

To

SHIV JYOTI CONVENT
SCHOOL, SHRINATHPURAM-D
Kota - (Raj)

(Name & Address of the Institution)



OFFICE OF THE SENIOR CHEMIST
REGIONAL LABORATORY, PHED, KOTA, RAJASTHAN
 PHED Campus, AKELGARH KOTA-324010



Test Report
(CHEMICAL & BACTERIOLOGICAL EXAMINATION OF WATER)

Desp. No. : **SS1**

Dated : **12/8/25**

Issued to:

Principal

**Shiv Jyoti Convent School Shrinathpuram-D
 Kota**

District: **Kota**

Block/City: **Kota**

Sample No: Collected by Lab

Ref ID	11			Sample Code No.	PC-77 PB-72
Reference : Letter No.		NM		Source :	R.O.
Reference Date:		06.08.25		Source Location :	Shiv Jyoti Convent School Shrinathpuram
Date of Receipt :		06.08.25		Habitation/Ward No. :	-
Sample ID	19				
Name of Sample Collector:		Sunit Sharma		Village/Colony/Nagar :	Kota
Designation of Sample Collector:		0		Gram Panchayat/City Area :	-
Latitude of Location				Date of Collection :	06.08.25
Longitude of Location				Start Date of Examination :	06.08.25
Elevation of Location				End Date of Examination :	12.08.25
Test Parameters		IS-10500:2012(RA 2018)		Sample Report No.	
		Requirement (Acceptable Limit)	Permissible limit in the absence of alternative sources	References Method:	Test Values
1	pH At Temp. 25 ⁰ C	6.5 to 8.5	No relaxation	[IS 3025, P-11], 2022	7.78
2	Turbidity	1.0	5.0	-	0.56
3	Taste	Not Defined	Not Defined	-	-
4	Odour	Unobjectionable	Unobjectionable	-	-
5	Total Alkalinity (as CaCO ₃) mg/l	200	600	[IS 3025, P-23], 1986 (RA2023)	60
6	Total Hardness (as CaCO ₃) mg/l	200	600	[IS 3025, P-21], 2009 (RA 2023)	50
7	Calcium (as Ca ⁺⁺) mg/l	75	200	[IS 3025, P-40], 1991 (RA 2024)	-
8	Magnesium (as Mg ⁺⁺) mg/l	30	100	[IS 3025, P-46], 1994 (RA 2023)	-
9	Chloride (as Cl ⁻) mg/l	250	1000	[IS 3025, P-32], 1988 (RA 2019)	30
10	Nitrates (as NO ₃ ⁻) mg/l	45	No relaxation	[APHA, Ed24, 4500-B] NO ₃ : 2022	4
11	Fluoride (as F ⁻) mg/l	1.0	1.5	[IS 3025, P-60], 2008 (RA 2023)	0.120
12	Total Dissolved Solids (TDS) mg/l At 180 ⁰ C	500	2000	[IS 3025 P-16]:1983 (RA 2023) [APHA, Ed24, 2510-B] Cond.2022	134
11	Total Coliform (MPN/100ml).	Nil	Nil	-	NIL

(*ADL= Above detection limit; BDL= Below detection limit)

**REPORT IS NOT VALID FOR
 JUDICIAL AND COMMERCIAL
 PURPOSE**

Authorized Signatory

[Signature]

Senior Chemist

PHED Reg.Lab. Kota

NOTE:

- 1 This test report shall not be reproduce except in full, unless permission for the reproduction of an approved abstract has been obtained from the Senior Chemist, REGIONAL LABORATORY PHED, KOTA (Rajasthan).
- 2 This test report reletes only to the samples/items submitted to the laboratory for test.
- 3 This report is not valid for legal cases/legal purposes.
- 4 Sample will be preserved only for 15 days from date of receipt.
- 5 Measurment of uncertainty and standard methods will be provided to customer on demand.

Telephone : 0744-2470946

E-mail: lab.kot.phed@rajasthan.gov.in

-----End of the Report-----